



NOTES:

1. ALL PIPE AND FITTINGS ABOVE GRADE SHALL HAVE FLANGED ENDS.
2. ALL PIPE AND FITTINGS BELOW GRADE SHALL BE MECHANICAL RESTRAINED JOINT ENDS.
3. PIPE SHALL BE COLOR CODED AND MARKED TO SEMINOLE CO. SPECIFICATIONS.
4. INSTALLATION SHALL COMPLY WITH ALL REQUIREMENTS OF 62-610 F.A.C.
5. PIPING AND APPURTENANCES SHALL BE PAINTED PANTONE PURPLE 522C. PVC PIPE SHALL BE COLORED FROM THE FACTORY WITH PANTONE PURPLE 522C USING LIGHT STABLE COLORANTS.
6. METER SHALL BE CAPABLE OF ACCURATELY MEASURING THE ENTIRE RANGE OF EXPECTED FLOWS AND THE TYPE AND MANUFACTURE SHALL BE APPROVED BY THE UTILITY.

3" AND LARGER RECLAIMED WATER METER